


Optimized Treatment of 1,4-Dioxane in Extracted Groundwater and Reinjection for Aquifer Replenishment


Steve Woodard, Ph.D, P.E.
President



Project location



Groundwater remediation lifecycle



**Current
Status**

Remediation timeline

1988: *Initiate Groundwater Extraction and Treatment with Thermal Oxidation/Carbon Adsorption*

1996: *Initiate Soil Vapor Extraction and Air Sparging*

2001: *Regulatory NFA for Soil Vapor Extraction/Air Sparging*

2003: *Convert Groundwater Treatment System to Bioreactor/Air Stripper/sand filter/Carbon Adsorption*

2004: *Regulatory NFA for Soil Impacts*


2008: *Convert Groundwater Treatment System to Advanced Oxidation Process (HiPOx[®])/Carbon Adsorption*

2011: *Regulatory NFA for Soil Vapor Intrusion*

2015: *WDR permit issued for full-scale *reinjection of treated groundwater**

2016: *Convert Groundwater Treatment to Synthetic Media System using AMBERSORB[™] 560*

What's being treated in groundwater?




max concentration / discharge limit in $\mu\text{g/L}$



Treatment complex

1,4-dioxane




- Stabilizer for chlorinated solvents, e.g. 1,1,1-TCA
- Wetting agent for polyester and paper processing
- Residue in cosmetics, shampoos, automotive coolants, fumigants



Quick refresher:

Why is 1,4-dioxane such a challenge to treat?

- Miscible in water
- Low volatility, low sorption
- Difficult to measure
- Difficult to remediate (recalcitrant)
- Travels rapidly in subsurface; plume often extends beyond extraction wells
- **Once discovered, often the driver for cleanup**



Installed bioreactor/air stripper/GAC in 2003



Converted to HiPOx in 2008




Outside view of HiPOx system



Inside view

Reinjection goals (year 2015)

- Maintain higher sustainable extraction rates during drought conditions (extraction yield dropped to < 5 gpm)
- Increase contaminant mass removal by enhanced soil flushing.
- Reduce contaminant mass/concentrations around the extraction well locations.
- Bypass NPDES monitoring for storm drain discharge



Challenges with AOP system

- Desorption of 1,4-dioxane from GAC polish vessels
- Drought conditions had caused reduced flowrate: 50 → 7 gpm
- High O&M costs – eventually became prohibitive
- Needed a new oxygen/ozone generator
- Wanted to get away from chemical use




Project objectives

- Perform lifecycle cost analysis of HiPOx upgrade/replacement options:
 - Upgrade existing HiPOx system
 - Replace with UV/Ox
 - Replace with Ambersorb
- Select best alternative
- Install/startup/operate for 8 to 12 more years

Synthetic media treatment system upgrade

AMBERSORB™ 560 (Ambersorb) adsorption system

- Carbonaceous resin with exceptional sorptive properties
- Removes 1,4-dioxane consistently to < 0.3 ppb
- Simple, low-maintenance system
 - Two media vessels in series (lead-lag operation)
 - Lead vessel periodically regenerated with steam
- No vapor discharge (eliminate AQMD permit)
- No carbon polish (eliminates desorption issue of 1,4-dioxane)




Ambersorb system design basis

Parameter	Design Condition	Effluent Limits
Average Flow Rate	2-24 gpm	--
Total VOCs	1,364 µg/L	Varies
1,4-dioxane	8.2 µg/L	≤ 3.0 µg/L
BTEX	642 µg/L	Varies
Influent Water Temp.	68-70°F	≤ 100°F
Regeneration	@ 7 gpm: Every 45 Days	--
Frequency	@ 24 gpm: Every 9 Days	--

Lifecycle cost analysis: Ambersorb vs. HiPOx

- Projected System Operations (~8 to 12 yrs)
- 7 gpm payout at 5 yrs
- 24 gpm payout at 8 yrs






Results and discussion

Ambersorb system first year operations

Parameter		Results
Flow	Cumulative	850,000 gallons
	average	4 gpm
1,4-dioxane Conc.	range	<1.0 µg/L to 79 µg/L
	average	31 µg/L
Influent Water Temp.	range	56°F to 98°F
	average	77°F
Regeneration Frequency	range	~45 days to ~90 days
	average	~60 days to ~90 days
Note: All discharge conditions were well within permit limits.		




Ambersorb Treatment System Module

Ambersorb system discharge compliance

February 2018 Summary

Monitoring Parameter	Discharge Limits	Units	Results
Total Dissolved Solids	1,700	mg/L	1,100
Chloride	270	mg/L	150
Sulfate	720	mg/L	330
Boron	1.0	mg/L	0.57
pH	6.5-8.5	SU	7.4
VOCs	Varies	ug/L	Non-Detect (all)
1,4-dioxane	3.0	ug/L	Non-Detect

Breakthrough Curves - Loading Cycles 1 Through 6



● LC#1 Lead Effluent

● LC#2 Lead Effluent

● LC#3 Lead Effluent

● LC#4 Lead Effluent

● LC#5 Lead Effluent

● LC#6 Lead Effluent

— Influent 14D Concentration

Summary of results / lessons learned

- Groundwater extraction/reinjection has been maintained at 2 to 10 gpm with minimal system maintenance.
- Ambersorb regeneration frequency has been low (typically 2 months between regens)
- Treatment has been fully effective (no effluent detections)
- O&M savings as projected
- Reinjection water is not fully captured by extraction wells
 - Response action includes temporary conversion from reinjection (WDR) to storm drain (NPDES)





Questions?

Steve Woodard

207-210-1551

swoodard@ect2.com

